


# Summer Outlook 2023

May 2023



[www.med-tso.org](http://www.med-tso.org)




Med-TSO is co-funded  
by the European Union.

## PURPOSE OF THE SUMMER OUTLOOK 2022/2023

This Brochure presents the adequacy results among non-EU Med-TSO members during this Summer 2023. With this assessment, Med-TSO is aligning with the world-wide best practices and the latest development of the EU regulations<sup>1</sup>.


In general, these investigations check whether available resources are sufficient to cover required electricity demand while complying with transmission grid operational security limit.



These investigations consider the security of electricity supply to consumers through a detailed power system adequacy assessment, using probabilistic criteria. This approach is inevitable due to the stochastic nature of renewable energy systems (RES), their intermittency and the power system operation which raise the question of power system adequacy in the short, mid, and long run. Moreover, the integration of immense amounts of RES must be closely followed by the commissioning of devices that can provide adequate power system flexibility.

With all the changes in the electricity sector in countries around the Mediterranean Sea - from the energy markets development, integration of renewable energy sources and efforts to decarbonise energy systems - adequacy monitoring becomes more and more important.

The Summer Outlook 2023 Report provides information about potential adequacy issues during the summer 2023 in seven MED-TSO members: **Morocco, Algeria, Tunisia, Libya, Egypt, Jordan and Lebanon:**



Med-TSO members that is analysed in this adequacy assessment

Med-TSO members that is not analysed in this adequacy assessment

Med-TSO members taking part to the ENTSO-E adequacy study

Data for Israel and Palestine are not available at the moment.



The analysed period includes all hours between the beginning of week 22 and the end of week 39 in 2023.

<sup>1</sup> <https://eur-lex.europa.eu/legal-content/EN/TXT/PDF/?uri=CELEX:32019R0943&from=en>

# APPROACH AND METHODOLOGY USED IN SUMMER OUTLOOK 2022/2023

As a general approach, a probabilistic Monte Carlo with Unit Commitment and Economic Dispatch (UCED) model has been used, ensuring inter-zonal and inter-temporal correlation of model variables and considering specificities of the assessed geographical perimeter. The hourly resolution has been implemented in the model and the Monte-Carlo approach has been used to reflect the variability of weather as well as the randomness of supply and transmission outages.

A number of Monte Carlo (MC) years are constructed to assess adequacy risks under various conditions for the analysed time-frame (see Figure below). For all those MC years, hourly calculations are performed for the whole geographical scope.



Collection of all relevant data and information necessary to model the power systems of Med-TSO has been realized with support from each TSO via forms specialized for collection of the data for different generation technologies, interconnections and demand. As an additional quality assurance, all provided data have been analysed and sanity checks were conducted.

Input data for the Summer Outlook 2023 have been collected in August/September 2022 and updated in December 2022.

The analyses have been carried out with the **ANTARES simulator**.

Seasonal adequacy assessment is based on the following main indicators:

➤ **P95/P50 Loss of Load Duration or Energy Not Supplied (P95/P50 LOLD/ENS)**




While LOLD in a given geographical zone for a given period is the number of hours during which the zone experiences ENS during a single Monte Carlo sample/simulation year, P95/P50 LOLD are LOLD in more or less severe operational conditions:

- P95: LOLD/ENS that happens once in 20 years
- P50: LOLD/ENS that happens once in 2 years

➤ **Loss of Load Expectation (LOLE) or Expected Energy Not Supplied (EENS)** in a given geographical zone for a given period is the expected number of hours per year when there is a lack of resources to cover the demand needs, within a sufficient transmission grid operational security limit or corresponding expected value of energy not to be supplied.

➤ **Dump Energy:** or RES curtailment, in a given geographical zone for a given period, is the energy generated in excess that cannot be balanced, for instance when the load is low and the in-feed from renewable is high.

➤ **The capacity Margin** for a given geographical zone for a given point in time is the difference between the available and engaged TPP capacity, as presented in the following diagram. These values point to the excess of capacity in the system.




## MAIN FINDINGS OF THE SUMMER OUTLOOK 2023

For probabilistic simulations, a total of 684 MC years have been constructed by combining climate-dependent variables (wind, solar and demand from 38 climatic years), available hydro time series and given/random outages:


- Climate years (each of 38 years from the period 1982- 2019) are selected one by one
- Each climate year is associated with random outage samples, i.e. randomly assigned unplanned outage patterns for thermal units.

The adequacy situation is assessed using a two-step approach:

- In the first step, adequacy under isolated system operation is evaluated.



- In the second, adequacy under interconnected system operation is assessed to quantify the importance of Med-TSO interconnections.



In the case of a theoretical isolated scenario, high adequacy risks are observed in some countries such as Lebanon, Libya and Tunisia & small or marginal in case of Jordan, Morocco and Algeria. Interconnections and energy exchanges with neighbouring countries reduce adequacy risks to zero or close to zero in Morocco, Algeria and Jordan, but, *in Lebanon, Libya and Tunisia, even in this more relaxed operating mode, adequacy risks are at unacceptable level.*


In the following tables ENS and LOLD seasonal results are given for all analysed countries.

Country	Isolated EENS	Interconnected EENS
DZ	25 MWh	0 MWh
	50TH percentile 0 MWh	50TH percentile 0 MWh
	95th percentile 0 MWh	95th percentile 0 MWh
EG	0 MWh	0 MWh
	50TH percentile 0 MWh	50TH percentile 0 MWh
	95th percentile 0 MWh	95th percentile 0 MWh
JO	113 MWh	19 MWh
	50TH percentile 0 MWh	50TH percentile 0 MWh
	95th percentile 64 MWh	95th percentile 0 MWh
MA	40 MWh	0 MWh
	50TH percentile 0 MWh	50TH percentile 0 MWh
	95th percentile 0 MWh	95th percentile 0 MWh
TN	34358 MWh	3128 MWh
	50TH percentile 4184 MWh	50TH percentile 0 MWh
	95th percentile 174670 MWh	95th percentile 16884 MWh
LY	13922 MWh	4787 MWh
	50TH percentile 0 MWh	50TH percentile 0 MWh
	95th percentile 102788 MWh	95th percentile 30216 MWh
LB	1028924 MWh	411607 MWh
	50TH percentile 966446 MWh	50TH percentile 327930 MWh
	95th percentile 1889403 MWh	95th percentile 1126837 MWh

Country	Isolated LOLE	Interconnected LOLE
DZ	0.06	0
	50TH percentile 0 hours	50TH percentile 0 hours
	95th percentile 0 hours	95th percentile 0 hours
EG	0	0
	50TH percentile 0 hours	50TH percentile 0 hours
	95th percentile 0 hours	95th percentile 0 hours
JO	0.82	0.16
	50TH percentile 0 hours	50TH percentile 0 hours
	95th percentile 3 hours	95th percentile 0 hours
MA	0.09	0
	50TH percentile 0 hours	50TH percentile 0 hours
	95th percentile 0 hours	95th percentile 0 hours
TN	123.04	13.79
	50TH percentile 46 hours	50TH percentile 0 hours
	95th percentile 534 hours	95th percentile 90 hours
LY	35.28	12.93
	50TH percentile 0 hours	50TH percentile 0 hours
	95th percentile 253 hours	95th percentile 104 hours
LB	1564.32	756.56
	50TH percentile 1566 hours	50TH percentile 698 hours
	95th percentile 2277 hours	95th percentile 1646 hours

Adequacy risk: ■ No risk ■ Very low risk ■ Low risk ■ Medium risk ■ High risk

Exchange directions and transfer capacity utilization of during 18 weeks of the 2023 summer season (average of all MC years) are presented on the following figure





Interconnections improves the adequacy situation in some of the countries but **present the inevitable support to adequacy in Lebanon, Libya, and Tunisia.**

## CONCLUSIONS

The conclusion is that during this summer no adequacy issues are expected in Algeria, Egypt, Jordan and Morocco. On the other hand, medium adequacy issues are expected to appear in Lebanon, Libya, and Tunisia. During entire summer period 2023 there is the highest probability that generation (+import) will not be sufficient to cover Lebanon's electricity demand. The main reason for that is a lack of generation capacities in Lebanon's generation mix and low level of cross border capacities. Similar situation appears in Libya, where the situation is the worst in period July-August





Med-TSO is the Association of the Mediterranean Transmission System Operators (TSOs) for electricity, operating the High Voltage Transmission Networks of 20 Mediterranean Countries. It was established on 19 April 2012 in Rome as a technical platform that, using multilateral cooperation as a strategy of regional development, could facilitate the integration of the Mediterranean Power Systems and foster Security and Socio – economic Development in the Region.

Med-TSO members share the primary objective of promoting the creation of a Mediterranean energy market, ensuring its optimal functioning through the definition of common methodologies, rules and practices for optimizing the operation of the existing infrastructures and facilitating the development of new ones.

Med-TSO Legal Headquarters  
Viale Egidio Galbani, 70 - 00156 Rome, Italy

Operational Headquarters  
Via della Marcigliana, 911 - 00138 Rome, Italy

Telephone +39 06 8313 9431 - Email: [info@med-tso.com](mailto:info@med-tso.com)



This product was created and maintained with the financial support of the European Union. Its contents are the sole responsibility of Med-TSO and do not necessarily reflect the views of the European Union